

Lindab LindQST MagiCAD Cloud Plugin for AutoCAD

13/04/2026

Content

1	GENERAL	3
1.1	How to install plugin	3
1.1.1	Required third-party software	3
1.1.2	Installation	3
2	STARTING THE PROGRAM	4
3	HOW TO USE THE PLUGIN	5
3.1	LindQST Selection tool.....	5
3.2	LindQST for silencers.....	9
3.3	LindQST for dampers	15
3.4	Open rooms.....	19

1 General

This document contains instructions on using LindQST plugin for MagiCAD for AutoCAD. The purpose of the plugin is to integrate selection- and indoor climate designer tool LindQST into MagiCAD for AutoCAD. It allows users to find and insert Lindab airborne, waterborne, silencer and damper products into MagiCAD project. In addition, plugin integrates LindQST indoor climate designer features into MagiCAD allowing users to design the air distribution in rooms.

1.1 How to install plugin

1.1.1 Required third-party software

LindQST MagiCAD plugin works with the following AutoCAD and MagiCAD versions:


- MagiCAD 2026 with AutoCAD 2023-2026
- MagiCAD 2027 with AutoCAD 2023-2027

1.1.2 Installation

1. Download setup file from
<https://portal.magicad.com/download/ProductSearch?searchStr=Lindab&categoryId=3>
2. Install the plugin by running the downloaded installer

2 Starting the program

You will find LindQST MagiCAD plugin ribbon panel under MagiCAD Connect tab in AutoCAD.



3 How to use the plugin

LindQST MagiCAD plugin contains 4 commands:


- LindQST Selection tool
- LindQST for silencers
- LindQST for dampers
- Opens rooms

3.1 LindQST Selection tool


This command opens LindQST for selecting suitable airborne or waterborne products into MagiCAD project.

Follow these steps to insert products from LindQST to MagiCAD project:

1. Click the “LindQST selection tool” button from LindQST plugin ribbon panel. Plugin opens LindQST in browser control window:




- Proceed by selecting either Airborne products or waterborne products. Here we proceed to Airborne product calculator (optionally you can also find suitable airborne products by clicking the Airborne Solutions from the main page):



In Airborne calculator proceed by making the required input and selections and then calculate the product. After that proceed by clicking the Export to MagiCAD button in order to insert the product to MagiCAD.


- LindQST view is closed and plugin Insert Products view is opened:




Product	Variant	User Code	System	Airflow (l/s)	Height level (mm)	2D Symbol
CRL-125-MBB-125-125-S4	CRL-125-MBB-125-125-	CRL1	Tuloilma 1	35	2800	Select...

Proceed by making required system selections, set height level and select suitable 2D symbol and airflow arrow for the product.

2D symbol can be selected by clicking the select... button from 2D symbol column. Select Symbol view is opened. Select 2D symbol and then click the OK button.




Lindab MagiCAD Plugin for AutoCAD - Insert

Product	Variant	User Code	System	Airflow (l/s)	Height level (mm)	2D Symbol
CRL-125-MBB-125-125-S4	CRL-125-MBB-125-125-	CRL1	Tuloilma 1	35	2800	Select... 

Select 2D Symbol for All... Insert Cancel

Once all selections have been made proceed by clicking the Insert button.

- Next product can be placed to MagiCAD drawing into wanted position:




3.2 LindQST for silencers

This command opens LindQST for selecting suitable silencer products into MagiCAD project.

Follow these steps to insert silencer from LindQST to MagiCAD project:

1. Click the “LindQST for silencers” button from LindQST plugin ribbon panel.
2. Select the duct where you want to add silencer to (this step can be skipped with ESC button):



3. LindQST silencer selector is opened. If you selected the duct in MagiCAD, information read from it is now populated automatically into corresponding fields in LindQST (fields highlighted in red):

Lindab MagiCAD Plugin for AutoCAD 2023.1.1

2 Silencer performance

State requirement in octave

Hz	63	125	250	500	1k	2k	4k	8k	dB(A)
L_{wt}	59	59	59	57	56	56	56	56	63
IL (Required)									
L_w (Required)	99	99	99	99	99	99	99	99	
L_{wo}									45

3 Technical requirements

Duct type: Circular

Silencer type: Straight

Product name: All

Duct connection size: 250

Air volume: 77 l/s




Max. total pressure loss: 50 Pa

Max. outer diameter: mm

Sound tolerance: dB


SEARCH RESULTS: 18

Number of products selected: 0

<input type="checkbox"/>	Order code	L [mm]	Δp [Pa]	L_{wa} [dB(A)]	v [m/s]
<input type="checkbox"/>	 PVA-250-1200-100	1200	0	45	1.6
<input type="checkbox"/>	 PVP-250-1200-50	1200	1	44	1.6
<input type="checkbox"/>	 PVD-250-1200-100	1200	0	44	1.6


Sound values are available only in case sound calculations have been performed in MagiCAD.

- Proceed by clicking the wanted product from the search results. Silencer calculator is opened.





Calculate the product and the click Export to MagiCAD button in order to insert calculated product into MagiCAD project.

- LindQST view is closed and MagiCAD user code and symbol selection view is opened:




2D symbol can be selected for the silencer by clicking the Select button:






Once all selections have been made proceed by clicking the OK button.

- Next MagiCAD insert view is opened, proceed by clicking OK button in order to place the silencer to the duct:






3.3 LindQST for dampers


This command opens LindQST for selecting suitable damper products into MagiCAD project.

Follow these steps to insert damper from LindQST to MagiCAD project:

1. Click the “LindQST for dampers” button from LindQST plugin ribbon panel.
2. Select the duct where you want to add damper to (this step can be skipped with ESC button):




3. LindQST damper calculator is opened. If you selected the duct in MagiCAD, information read from it is now populated automatically into corresponding fields in LindQST (fields highlighted in red):





4. Proceed by selecting the wanted product and calculate it. Then click Export to MagiCAD button in order to insert selected damper into MagiCAD project.

5. LindQST view is closed and MagiCAD user code and symbol selection view is opened:





Property	Value
Product variable	
National code	
Installation code	Not selected
National classification ...	
HyperLink	
ifcExportAs	ifcDamperType (IFC2X3, IFC4)
ifcType	BALANCINGDAMPER (IFC2X3, ...)
P1	
P2	
P3	
P4	
P5	
P6	
P7	
P8	
P9	
P10	
P11	
P12	
P13	

2D symbol can be selected for the damper by clicking the Select button.



Once all selections have been made proceed by clicking the OK button.

- Next MagiCAD insert view is opened, proceed by clicking OK button in order to place the damper to the duct:




3.4 Open rooms

Open Rooms command allows user to select the room area(s) from MagiCAD drawing and export the room geometries to LindQST. User can add products to the rooms in LindQST Indoor climate designer and take advantage of the room functionalities in LindQST. Once the ventilation design for the rooms is ready, user can insert products to MagiCAD drawing.

Follow these steps to use the Open rooms command:

1. Click Open Rooms command from the plugin ribbon panel.
2. Room selection type dialog is opened.




From this view user can choose the way to show the room area. Following options are available:


- Draw room area with rectangular tool
- Draw room area with line tool

In this example case we choose to use rectangular tool as the room we are going to select has rectangular shape. Notice that also the room height is defined in the dialog above. By default it has the height level defined in MagiCAD floor settings. Once the selections have been made click Select Room button.

- Proceed by showing the room area with rectangular tool:




- Once the area has been selected, the room selection type dialog is opened again allowing you to either select another room or continue to LindQST with already selected rooms.




In this example case we click now Open LindQST button in order to open selected room in LindQST Indoor climate designer. Optionally user could select another room first by clicking Select Room button.



- LindQST Indoor climate designer is opened, and the selected room area is loaded:




- Proceed for example by adding wanted products to the room(s):




7. Select product and click Add to project.




8. Add another product if needed.




9. Added products are loaded to the room, and placed into the default location. Click Edit button in order to position the products.






10. Once products are in place and you have finished modifying the room in LindQST, proceed by clicking the Import back to drawing button in order to send added products to MagiCAD:




11. LindQST is closed and Insert Products view from the plugin is opened:





Select required systems for the products. Also 2D symbol can be selected for airborne products. Once selections have been made click Insert button.

12. Products are now placed to the drawing into locations defined in LindQST Indoor climate designer.



The command is now completed.

13. Room can be re-opened with Open rooms command if needed. When the room is opened again, also the existing products in the room are recognized and transferred to LindQST.



14. User can add more products to the room or modify the existing ones if needed. Once modifications to the products have been made, updates can be sent back to MagiCAD by clicking the Import back to drawing button.